



CEILING FINISHED AS SPECIFIED

2x4 (38x89mm) CONT. TO MATCH ROOF TRUSS
 BOTTOM CHORD FASTENED THROUGH TO CAVITY
 (PRE-POUR)

FORM TO BE KERF CUT (POST POUR) TO CONCRETE (CONT.)
 GYPSUM BOARD OF CEILING TO BE INSERTED & CAULKED TO CONCRETE WITH APPROVED FIRE STOP CAULKING

ATTIC INSULATION AS SPECIFIED OR AS PER CODE MINIMUM

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

5/8" (16mm) TYPE 'X' GYPSUM BOARD

DISCLAIMER NOTICE:
 SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 6" (152mm) FORM UNIT
 STC / FIRE WALL DETAILS
 CEILING CONNECTION
 WOOD TRUSSES

REV. NO.
003 KS
 REV. DATE:
AUGUST 2010
 DRAWN BY:
T. VAN CLIEAF

DWG NO.
FW6D3
 SCALE:
1 : 8