



CEILING FINISHED AS SPECIFIED

2x4 (38x89mm) CONT. TO MATCH ROOF TRUSS BOTTOM CHORD FASTENED THROUGH TO CAVITY (PRE-POUR)

FORM TO BE KERF CUT (POST POUR) TO CONCRETE (CONT.) GYPSUM BOARD OF CEILING TO BE INSERTED & CAULKED TO CONCRETE WITH APPROVED FIRE STOP CAULKING

ATTIC INSULATION AS SPECIFIED OR AS PER CODE MINIMUM

NUDURA 8" (203mm) STANDARD FORM UNIT

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

5/8" (16mm) TYPE 'X' GYPSUM BOARD

DISCLAIMER NOTICE:
 SPECIFIC INFORMATION
 REQUIRED FOR COMPLIANCE
 WITH LOCAL CODES IS THE
 RESPONSIBILITY OF THE
 DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 8" (203mm) FORM UNIT
 STC / FIRE WALL DETAILS
 CEILING CONNECTION
 WOOD TRUSSES

REV. NO. 001 KS	DWG NO. FW8D3
REV. DATE: AUGUST 2010	
DRAWN BY: K. STILL	SCALE: 1 : 8